KILOMETER POST SHEET TOTAL TOTAL PROJECT NO SHEET

12.2/14.3 407g 0.0/4.0 08S41 1204

# NOTES:

1. For splice cable tray support details, see sheet E-836.


COUNTY

80

04 SF,Ala

## **SHEET NOTES:**

- Cable tray bonding jumper assembly shall be Cooper B-Line Catalog #99-40 or approved equal. Mounting hardware shall be hot dipped galvanized steel, ribbed neck carriage bolt, serrated flange hex nut, flat and lock washers.
- See sheet E-836, Table A for conduit location and designation number.



# PLAN - DETAIL 7

TOS/COM Splice Cable Tray installation between diaphragms

#### REQUEST FOR INFORMATION NOT ADDRESSED IN THIS CCO REMAIN IN FORCE RG SYC FW 110 03/08/10 MEP INTEGRATION MARK DATE DESCRIPTIONS BY CH'D CCO# REVISIONS CONTRACT CHANGE ORDER NO. SHEET OF


# **DETAILS** BRIDGE STRUCTURES GIRDER EASTBOUND GIRDER TYPICAL DETAILS

NO SCALE


E-836A

8 8

#4/0, 15 kV cable (three phase) 750 meter (Max) Supply Side Cable shield. termination (Typ) Ground cable shield at supply maximum potential side only. Connect phase A, B and C shields to system ground conductor



### SHIELD GROUNDING - DETAIL 3



### PLAN - DETAIL 6

15 kV Splice Cable Tray installation between diaphragms See E-835 for Splice Cable Tray Location

ALL DIMENSIONS ARE IN MILLIMETERS UNLESS OTHERWISE SHOWN

THIS PLAN ACCURATE FOR ELECTRICAL WORK ONLY.

REVISED

DATE

01/10

BY

REVISED

SYC

CALCULATED/ DESIGNED BY CHECKED BY

**GOLEMOHAMMAD I** 

TRANSPORTATION

DEPARTMENT OF

CALIFORNIA

능

**GIV** 

FOR REDUCED PLANS ORIGINAL SCALE IS IN MILLIMETERS

DGN FILE =>04-0120f1\_E-836A.dgn USERNAME => | lorico

CU 04251

EA 0120F1